General Specifications

GS 01E24A21-04EN

ADMAG TI Series AXW Electromagnetic Flowmeter [Size: 25 to 400 mm (1 to 16 in.)] Marine Approval Type



OUTLINE

This General Specifications describes ADMAG TI Series AXW Electromagnetic Flowmeter [Size: 25 to 400 mm (1 to 16 in.)] for Marine Approval Types. For standard specifications, functions, other optional specifications, limitation and separate table, please refer to the General Specifications as below.

Document Name	Document No.
ADMAG TI Series AXW Electromagnetic Flowmeter	GS 01E24A01-01EN
[Size: 25 to 400 mm (1 to 16 in.)]	

Note: AXW Electromagnetic Flowmeter [Size: 500 to 1800 mm (20 to 72 in.)] is handled as special products. Therefore, please contact Yokogawa's sales office when ordering.

CONFORMITY STANDARDS

In addition to CONFORMITY STANDARDS described in the general specifications of ADMAG TI Series AXW Electromagnetic Flowmeter [Size: 25 to 400 mm (1 to 16 in.)], following marine approval have been approved. Please refer to GS 01E24A01-01EN for other specifications.

Marine Approval:

Det Norske Veritas Type Approval Approval/Cert.no: TAA00002H4

Location classes:

Temperature	D
Humidity	В
Vibration	А
EMC	А
Enclosure	C (IP66/IP67)
URL:	

https://approvalfinder.dnvgl.com/#approval/TAA00002H4

MODEL AND SUFFIX CODE

The model name and basic specification code of the classification type product of ADMAG TI Series AXW Electromagnetic Flowmeter [Size: 25 to 400 mm (1 to 16 in.)] are described. Please refer to GS01E24A01-01EN for the ADMAG TI Series AXW Electromagnetic Flowmeter for optional codes.

Note:

- There are some limitations on the combination of specifications. Read specification code table when selecting specification code.
- 2: For EN standard wafer and flange type of sizes 25 to 50 mm (1 to 2 in.), select PN40 even for lower pressure rating because the dimensions of mating faces for PN10, 16, and 40 are the same.

For EN standard wafer and flange type of sizes 65 to 150 mm (2.5 to 6 in.), select PN16 even for lower pressure rating because the dimensions of mating faces for PN10 and 16 are the same.





Integral Flowmeter

Remote Transmitter

- 3: The dimensions of mating faces are based on the following flange standards. The usable range is also limited by fluid temperature and pressure conditions. JIS F12: JIS G 3443-2, JIS 10K, 20K: JIS B 2220 and JIS G 3443-2, ASME: ASME B 16.5, EN: EN 1092-1
- 4: In the case of size from 25mm to 400mm, the grounding device is selectable from none or grounding ring. When selecting the grounding ring, it is also necessary to select its type (material etc.) from the optional codes.
- 5: The lay length (face to face) of the flange type of polyurethane rubber, natural hard rubber, and natural soft rubber lining conforms to ISO standard (ISO 20456). The lay length depends on the presence or absence of the optional grounding rings or gaskets, so see the Dimensional Drawings.
- 6: Lining, electrode, and grounding device (grounding ring plate) are wetted parts. Users must consider the characteristics of selected wetted parts material and influence of process fluids. The use of inappropriate materials can result in the leakage of corrosive process fluids and cause injury to personnel and/or damage to plant facilities. It is also possible that the instrument itself can be damaged and that fragments from the instrument can contaminate the user's process fluids. Be very careful with highly corrosive process fluids such as hydrochloric acid, sulfuric acid, hydrogen sulfide, sodium hypochlorite, and high-temperature steam (150°C [302°F] or above). Contact Yokogawa for detailed information of the wetted parts material.
- 7: In the case of remote sensor from 25mm to 400mm, select "None (or Without)" for each specification code of "Power Supply", "Communication and I/O", "Transmitter Wiring Terminal" and "Display".
- 8: In the case that final destination is Taiwan and explosion type is required, select IECEx flameproof type.
- 9: When combining IECEx Flameproof and CE marking, it is limited to applications mounted on seagoing vessels.
- 10: A For Power Cord -1, TDK ferrite core ZCAT3035-1330 is attached to the product. Be sure to attach the ferrite core to the wiring port side of the cable connected to the I/O terminal.
- 11: A Specify the cable length for remote type up to 5 m (16 feet).



Yokogawa Electric Corporation 2-9-32, Nakacho, Musashino-shi, Tokyo, 180-8750 Japan Tel.: +81-422-52-4443 Fax.: +81-422-52-2018 GS 01E24A21-04EN © Copyright June 2020 (KP) 2nd Edition Dec. 24, 2021 (KP)

•General-purpose	Submersible,	Explosionprotection,	Wafer, Flange
------------------	--------------	----------------------	---------------

			<u> </u>	D 14	
Model		Su	ffix Code	Description	Limitation
AXW025				Electromagnetic Flowmeter (25 mm/1 in)	
AXW032				Electromagnetic Flowmeter (32 mm/1.25 in)	
AXW040				Electromagnetic Flowmeter (40 mm/1.5 in)	
AXW050				Electromagnetic Flowmeter (50 mm/2 in)	
AXW065				Electromagnetic Flowmeter (65 mm/2.5 in)	
AXW080				Electromagnetic Flowmeter (80 mm/3 in)	
AXW100				Electromagnetic Flowmeter (100 mm/4 in)	
AXW125				Electromagnetic Flowmeter (125 mm/5 in)	
AXW150				Electromagnetic Flowmeter (150 mm/6 in)	
AXW200				Electromagnetic Flowmeter (200 mm/8 in)	
AXW250				Electromagnetic Flowmeter (250 mm/10 in)	
AXW300				Electromagnetic Flowmeter (300 mm/12 in)	
AXW350				Electromagnetic Flowmeter (350 mm/14 in)	
AXW400				Electromagnetic Flowmeter (400 mm/16 in)	
	-G			General-purpose	
Use	-C			Explosion protection	
	-W			Submersible	Only for Remote Sensor
	A			Integral Flowmeter	
Construction W				Remote Sensor (for AXW4A)	
		000		Non Explosion Protection Approval	
Explosion		KF2		ATEX Flameproof	See Restriction for Explosion Protection type in GS01E24A01-01EN
Protection S		SF2		IECEx Flameproof	See Note 8, 9 and Restriction for Explosion protection type in GS 01E24A01-01EN
		AA1		ASME Class 150 Wafer	25 to 200 mm (1 to 8 in.)
		AA2		ASME Class 300 Wafer	25 to 200 mm (1 to 8 in.)
		AE1		EN PN10 Wafer	200 mm (8 in.)
		AE2		EN PN16 Wafer	65 to 200 mm (2.5 to 8 in.)
	Wafe	r AE4		EN PN40 Wafer	25 to 50 mm (1 to 2 in.)
		AG1		JIS F12 Wafer	80 to 200 mm (3 to 8 in.)
		AJ1		JIS 10K Wafer	25 to 200 mm (1 to 8 in.)
		AJ2		JIS 20K Wafer	25 to 200 mm (1 to 8 in.)
		BA1		ASME Class 150 Flange	
		BA2		ASME Class 300 Flange	25 to 300 mm (1 to 12 in.)
		DEA		·	200 to 400 mm (8 to 16 in.)
_	Stainl	ess		EN PN10 Flange	
Process	Steel	BE2		EN PN16 Flange	65 to 300 mm (2.5 to 12 in.)
Connection	Flang (F304	\ <u> </u>		EN PN40 Flange	25 to 50 mm (1 to 2 in.)
	1,1004	001		JIS F12 Flange	80 to 400 mm (3 to 16 in.)
		BJ1		JIS 10K Flange	
		BJ2		JIS 20K Flange	25 to 300 mm (1 to 12 in.)
		CA1		ASME Class 150 Flange	50 to 400 mm (2 to 16 in.)
		CA2		ASME Class 300 Flange	50 to 300 mm (2 to 12 in.)
	0-1	CE1		EN PN10 Flange	200 to 400 mm (8 to 16 in.)
	Carb Steel	CE2		EN PN16 Flange	65 to 300 mm (2.5 to 12 in.)
	Flang			EN PN40 Flange	50 mm (2 in.)
		CG1		JIS F12 Flange	80 to 400 mm (3 to 16 in.)
		CJ1		JIS 10K Flange	50 to 400 mm (2 to 16 in.)
		CJ2		JIS 20K Flange	50 to 300 mm (2 to 12 in.)
		F		PTFE Lining	Applicable for Flanges only. Not applicable for Submersible
Lining		U		Polyurethane Rubber Lining	
		Н		Natural Hard Rubber Lining	50 to 400 mm (2 to 16 in.)
		D		Natural Soft Rubber Lining	50 to 400 mm (2 to 16 in.)
Erectrode			L	Stainless Steel 316L	
			H	Nickel Alloy	
	Davis		1	None	
Grounding			2	Grounding Rings	Select an optional code

(Continued)

1					Standard Material with Standard Coating	
Housing and Coating	2				Standard Material with Rugged Coating	Not applicable for Submersible
	0				JIS G1/2 Female	See Restriction for Explosion Protection type
Cable Entry		2			ASME 1/2 NPT Female	Not applicable for Submersible, See Restriction for Explosion Protection type
		4			ISO M20×1.5 Female	Not applicable for Submersible, See Restriction for Explosion Protection type
Accuracy	В				Standard	
		-	-1 -2		100-240 V AC / 100-120 V DC	Only for Integral Flowmeter
Power Supply		-			24 V AC / DC	Only for Integral Flowmeter
	-	-N		None (Remote Sensor)	Only for Remote Sensor	
Communication and I/O M#					#: A, E, G HART 7 and I/O (Type A, E, G, See separate table)	Only for Integral Flowmeter
					#: 0, 6 Modbus and I/O (Type 0, 6, See separate table)	Only for Integral Flowmeter
NN					None (Remote Sensor)	Only for Remote Sensor
Transmitter Wiring Terminal 2 N				1	M4 Screw-type	
				2	Clamp Type	
				N	None (Remote Sensor)	Only for Remote Sensor
Display 1 N				1	With Display (English, Multi-language)	Only for Integral Flowmeter
				2	With Display (English, Chinese)	Only for Integral Flowmeter
				Ν	Without Display/Remote Sensor	

•General-purpose, ExplosionProtection, Remote Transmitter

Model	Suffix Code				ix Co	de		Description	Limitation
AXW4A								Electromagnetic Flowmeter Remote Transmitter	
Line	-G				General-purpose				
Use	-C	-C						Explosion protection	
		000						Non Explosion Protection Approval	
Explosion	KF2		2			ATEX Flameproof	See Restriction for Explosion Protection type in GS 01E24A01-01EN		
Protection		SF2	SF2					IECEx Flameproof	See Note 8, 9 and Restriction for Explosion protection type in GS 01E24A01-01EN
Housing a	nd		1					Standard Material with Standard Coating	
Coating						Standard Material with Rugged Coating			
Cable Entry 2		0			JIS G1/2 Female	See Restriction for Explosion Protection type			
		2				ASME 1/2 NPT Female	See Restriction for Explosion Protection type		
			4	4			ISO M20×1.5 Female	See Restriction for Explosion Protection type	
Douvor Cu	anlı			1				100-240 V AC / 100-120 V DC	
Power Su	spiy			2				24 V AC / DC	
Communication and I/O			#: A, E, G HART 7 and I/O (Type A, E, G, See separate table)						
		M#			#: 0, 6 Modbus and I/O (Type 0, 6, See separate table)				
Tropomitte	vr \\/:	ing To	rmin			1		M4 Screw-type	
Transmitte		ing le	::::::::	aı		2		Clamp Type	
1		1	With Display (English, Multi-language)						
Display							2	With Display (English, Chinese)	
· · ·		Γ	N	Without Display/Remote Sensor					

•Signal Cable

Model	Suffix Code	Optional Code	Description
AX01C			Electromagnetic Flowmeter Signal Cable
Cable Finish and	-A### (*1)		Unfinished, Cable length ### m, Set of Finishing Parts for M4 Screws
Length	-C### (*1)		Finished for AXW4A, Cable Length ### m
Finishing Parts		/C# (*2)	Finishing Parts (# sets)

*1: Specify the cable length in the "###" with the numerical value three digits (001 to 200) as multiple of 1 meter (e.g. 001, 002, or 005) for a length up to 5 m, as multiple of 5 meters up to 100 m (e.g. 010, 020, or 100), or as multiple of 10 meters up to 200 m (e.g. 110, 120, or 200). The maximum cable length: -A###: 200 m,-C###: 5 m

*2: Specify the finishing parts quantity in the "#" with the numerical value one digit (1 to 9).

OPTIONAL CODE

Item	Specification and Applicable Condition	Code
Marine Approval	Det Norske Veritas Type Approval Approval/Cert.no: TAA00002H4	WCD

For other optional codes, refer to the general specifications (GS 01E24A01-01EN).

Be sure to add / WCD to applications that require Marine approval.

ACCESSORIES

- · Centering Device (wafer type only): 1 set
- Blanking Plug: 1 to 2 pcs.
- Gasket (sensor side): 2 sheets
- Mounting (transmitter only): 1 set
- Ferrite Core (Power Cord -1): 2pcs.

Note: Accessories differ depending on specifications to be selected.

For TERMINAL CONFIGURATION and ORDERING INFORMATION, refer to GS01E24A01-01EN.

TRADEMARKS

Det Norske Veritas is a registered trademark of Det Norske Veritas Group.

HART is a registered trademark of FieldComm Group.

Modbus is a registered trademark of AEDG Schneider.

ADMAG, AXG, AXW, BRAIN TERMINAL, and FieldMate are registered trademarks of Yokogawa Electric Corporation. All other company and product names mentioned in this document are trade names, trademarks or registered trademarks of their respective companies.

In this document, trademarks or registered trademarks are not marked with ™ or ®.

<Information on EU WEEE Directive>

EU WEEE (Waste Electrical and Electronic Equipment) Directive is only valid in the EU.

This instrument is intended to be sold and used only as a part of equipment which is excluded from WEEE Directive, such as large-scale stationary industrial tools, a large-scale fixed installation and so on, and, therefore, subjected to the exclusion from the scope of the WEEE Directive. The instrument should be disposed of in accordance with local and national legislation/regulations.